



Ventura County Environmental Health Division  
 800 S. Victoria Ave., Ventura CA 93009-1730  
 TELEPHONE: 805/654-2813 or FAX: 805/654-2480  
 Internet Web Site Address: [www.ventura.org/rma/envhealth](http://www.ventura.org/rma/envhealth)

### Daily Log of Pool Chemistry

Name of Pool Facility	Location/Address	Name of Pool Service Company	Phone No. Pool Service
-----------------------	------------------	------------------------------	------------------------

Date	Pool Type Pool, Spa, Wader, ect	Free Chlorine <sup>1</sup>	pH <sup>2</sup>	Controller ORP	Controller pH	Spa Temp.	Flow rate (gpm)	Influent gauge	Remarks: e.g., filters cleaned/backwashed, equipment repairs, chemicals added (type/amounts)	Operator initials

Monthly Test	Cyanuric Acid (Cl <sub>2</sub> stabilizer)	Total Alkalinity	Calcium Hardness	Remarks:
Date	Ideal Range 20-40 ppm Max 100 ppm	Ideal Range 80-110 ppm	Ideal Range 200-400 ppm	Operator's Initials

<sup>1</sup>Free chlorine residual: Swimming Pool minimum 1.0 ppm un-stabilized and 2.0 ppm stabilized, and a maximum of 10.0 ppm.  
 Spa, Sprayground, Wader minimum of 3.0 ppm and maximum of 10.0 ppm.  
<sup>2</sup>pH: Required range: 7.2 – 7.8