

Section 105.2 of the IBC is amended in the VCBC to read as follows:

105.2 Exempted work

Electrical: *An electrical permit will not be required for the following:*

1. **Repairs and maintenance:** Minor repair work, including the replacement of lamps or the connection of approved portable electrical equipment to approved permanently installed receptacles.
2. **Radio and television transmitting stations:** The provisions of this Code shall not apply to electrical equipment used for radio and television transmissions but do apply to equipment and wiring for a power supply and the installations of towers and antennas.
3. **Temporary testing systems:** A permit shall not be required for the installation of any temporary system required for the testing or servicing of electrical equipment or apparatus.
4. *Portable motors or other portable appliances energized by means of a cord or cable having an attachment plug end to be connected to an approved receptacle when that cord or cable is permitted by this Code.*
5. *Repair or replacement of fixed motors, transformers, or approved fixed appliances of same type and rating and in the same location.*
6. *Temporary decorative lighting energized by cord or cable having an attachment plug end to be connected to an approved receptacle.*
7. *Reinstallation of attachment plug receptacles but not the outlets therefor.*
8. *Replacement of an overcurrent device of the same capacity and in the same location.*
9. *Repair or replacement of electrodes or transformers of the same size and capacity for approved signs or gas tube systems.*
10. *Removal of abandoned electrical wiring.*
11. *Electrical wiring, devices, appliance or equipment operating at less than 25 volts and not capable of supplying more than 50 watts of energy.*
12. *Low-energy power, control and signal circuits of Class II and III as defined in this Code.*